Carrier **ClimaVision** | SITE PRECONFIGURATION

POWERED BY 75F

SITE DETAILS (Please ensure all fields are filled out)

Site Name

CCU Name

Organization Name

Timezone

Street Address

City

State

Country

ZIP Code

Facility Manager Email

Billing Admin Email

SYSTEM PROFILE: VVT-C STAGED RTU WITH VFD FAN (Select (✓) a required configuration)

- [ ] Cooling Stage 1 (Relay 1)
- [ ] Cooling Stage 2 (Relay 2)
- [ ] Heating Stage 1 (Relay 4)
- [ ] Heating Stage 2 (Relay 5)
- [ ] Run Fan Stage 2 during heating/cooling stage 2 (Relays 6)

Fan Stage (Select only one required configuration for Relay 3)

- [ ] Run Fan Stage 1 during occupied time & heating/cooling call in unoccupied (Fan Enable)
- [ ] Run Fan Stage 1 only during heating/cooling call (Fan Stage 1)

FLOOR & ZONE NAMES (Please provide the details for the required zones)

Floor Name

1. Zone Name

2. Zone Name

3. Zone Name

For additional zones, address has to be set manually on the Smart Nodes.
Ask your AI assistant for instructions

4. Zone Name (Pairing Address: 1004)

5. Zone Name (Pairing Address: 1005)

6. Zone Name (Pairing Address: 1006)

Download ClimaVision for Facilities
Scan QR code

Learn more with Climavision Video Tutorials
Scan QR code